



IBFE

Institut für Biotechnische
Forschung und Entwicklung

Konrad-Zuse-Str. 10A
66459 Kirkel-Limbach

aquaBENOVA GmbH

Mr. Thomas Graf
Bahnhofstr. 18
86420 Diedorf

Contact: Dr. Heiko Ewen (Head of laboratory)
Phone: 06841 18997-50
Fax: 06841 18997-79
E-mail: info@ibfe-biotech.de

Report No.: 471012-d

Sample material:	aquaBENOVA-CLEAN – drinking water disinfection, in a plastic container	IBFE No: 471012
Project:	aquaBENOVA GmbH	
Testing number:	471012	
Customer:	aquaBENOVA GmbH	
	Yr. Order from:	02.10.2012
	Sample receipt:	08.10.2012
	Start of analysis:	15.10.2012
	End of analysis:	18.10.2012

Assay for a test with *Pseudomonas aeruginosa*:

2 x 1 litre of sterile tap water were contaminated with *Pseudomonas aeruginosa* to get a total cell concentration of 4.9 million *Pseudomonas aeruginosa* per litre water. One preparation was treated with 1.5 ml aquaBENOVA-CLEAN and mixed thoroughly. The other preparation was not treated and served as a control for the viability of the test organism during the trial period. At the times mentioned in the table below the germ content of both preparations was determined. The spatula method on CN - agar was used for the untreated preparation and respectively 100 ml of the aquaBENOVA-CLEAN treated preparation were filtered according to DIN EN ISO 16266.

Incubation time	Germ content of <i>Pseudomonas aeruginosa</i> in untreated tap water	Germ content of <i>Pseudomonas aeruginosa</i> in tap water treated with aquaBENOVA-CLEAN
1 hour	> 200 <i>Pseudomonas aeruginosa</i> in 100 ml	2 <i>Pseudomonas aeruginosa</i> in 100 ml
3 hours	> 200 <i>Pseudomonas aeruginosa</i> in 100 ml	<i>Pseudomonas aeruginosa</i> not detectable in 100 ml

Conclusion:

One litre of water was contaminated with a number of 4.9 million *Pseudomonas aeruginosa*. After addition of 1.5 ml aquaBENOVA-CLEAN and an incubation time of 3 hour, the water complied with the "German Drinking Water Ordinance" (TrinkwV 2001; maximum permissible value: *Pseudomonas aeruginosa* not detectable in 100 ml) regarding to the bacterium *Pseudomonas aeruginosa*, since in 100 ml of such treated water no viable *Pseudomonas aeruginosa* could be detected.

Kirkel-Limbach, 28th of January 2013

reviewed and approved


(Dr. Heiko Ewen, Head of Laboratory / Quality Control)

1/1

The results refer exclusively to the tested samples. The accreditation applies for the testing methods denoted in the accreditation. It is prohibited to copy parts of this report without the written authorisation of IBFE GmbH.

Geschäftsführung: Holger Graf

Registergericht: HR Saarbrücken B 14445 | USt-Id. Nr.: DE 232594386 | Steuer-Nr.: 075/111/00571
Bankverbindung: Kreissparkasse Saarpfalz | BLZ: 594 500 10 | Konto: 1011036447
IBAN: DE 71 5945 0010 1011 0364 47 | Swift-Bic: SALADE51HOM

